UNIT COOLING TOWER			G. # AX122209-DRC-ST REV
MODEL # SCALE AXS 12-11J22	EVAPCO, IN	SER	DATE 5/16/2024
NOTES: 1. (M)- FAN MOTOR LOCATION 2. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED 3. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 4. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 5. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING. 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH IN [METRIC] [mm]	FACE B PLAN VIEW 5'-11" [1804]	FACE C ACCESS DOOR 8 1/8" FACE A	(2) 8" [200] ASME 150 BOLT PATTERN INLET FACE D
7" [178]	3/8" [2'-3 1/4"] 3/8" [692] 1'-6 7/8"] [479] 8 1/2" [216] 3 3/8"	ACCESS DOOR 10" [250] BFW/GVD OUTLET 22'-9" [6934] FACE A	2" [50] MPT MAKE-UP 3" [80] FPT OVERFLOW 3" [80] FPT DRAIN
	RATING EIGHT 26160 lbs+ [11870] kg+	IEAVIEST SECTION 11970 lbs+ [5430] kg+	NO. OF SHIPPING SECTIONS 1 DRAWN BY: JLM