UNIT COOLING TOWER		E\/A	DCO T	NC eve	apeo	DWG. # T4285260-DRA-ST	REV
10DEL # AT 428-5M52	SCALE NTS	TEVA	APCO, I	NC.	3	SERIAL #	DATE 5/2/2024
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS UPP 3. MPT DENOTES MALE PIPE FPT DENOTES FEMALE PIPE BFW DENOTES BEVELED F GVD DENOTES GROOVED FLG DENOTES PLAIN END 4. +UNIT WEIGHT DOES NOT ACCESSORIES (SEE ACCES 5. MAKE-UP WATER PRESSUE 20 psi MIIN [137 kPa], 50 psi M REFER TO RECOMMENDED DRAWING 7. DIMENSIONS LISTED AS FOEN ENGLISH FT-IN [METRIC] [mm] 8. PAN FLUME BOX EQUALIZE EVAPCO. PAN EQUALIZER IS BY OTHERS. 9. PAN EQUALIZER NIPPLE IS OFF EACH STEP SIDE.	ER SECTION THREAD E THREAD OR WELDING INCLUDE SSORY DRAWINGS) RE MAX [344 kPa] 5 HOLES. 0 STEEL SUPPORT OLLOWS: ERS SUPPLIED BY PIPING IS SUPPLIED		FACE B PLAN VIEW		(8) ACCESS DOOR		FACE D
		_ 1'-3 1/4" _ [387]	7" [178]		FACE F	<u>\</u>	
(4) 14" [350] BFW/GVD INLET		6'-11 5/8" [2124] 22'-3 1/2 [6794	12'-1/4" [3664] [51]	00	00	00 00	2" [51]
		16'-3 3/4" [4972]	10'-3 1/4" [3131]				,
(4) 14" [350]	11'-6" [3505] 13'-1 1/4" [3994] 13'-5 1/2" [4102] 13'-6 1/2" [4128]	2'-2" [660] _ 1'-5 3/8" [441] _ 9" [229]		. 25'-9 [7849	9 1/8" [232] 1 3/8" [35]	(4) 12" [300] BFW/GVD EQUALIZER (SEE NOTE #9) 3'-7" [1092]	
5 1/8"	13'-11 1/4"			. 7043			
28'-3 5/8" [8626] FACE B		1 1/2" 1 1/2" [16789] 1 1/2" [38]					
SHIPPING 98600 lbs+ [44725] kg+ WEIGHT		OPERATING 165160 WEIGHT	lbs+ [74920] kg+	HEAVIEST SECTION WEIGHT	17820 lbs+ [8085] kg+	NO. OF SHIPPING SECTIONS 8	DRAWN BY: MER