UNIT COOLING TOWER		lo evanço	NG. # AX122209-DRC-ST REV	
MODEL # SCALE AXS 12-11N22	EVAPCO, IN	SE	DATE 5/19/2	:024
NOTES:  1. (M)- FAN MOTOR LOCATION  2. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED  3. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)  4. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]  5. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING.  6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH IN [METRIC] [mm]	FACE B PLAN VIEW  5'-11" [1804]	FACE C ACCESS DOOR  8 1/8" 207 ]  FACE A	(2) 8" [200] ASI 150 BOLT PATT INLET  FACE D	:ME ГЕRN
7" [ 178 ]	11'-4 1/4" [ 3461 ]  3/8" [ 692 ]  1'-6 7/8"   [ 479 ]  8 1/2"   [ 216 ]  3 3/8"   [ 86 ]	ACCESS DOOR  10" [250] BFW/GVD OUTLET  22'-9" [ 6934 ]  FACE A	2" [50] MPT MAKE-UP  3" [80] FPT OVERFLOW  3" [80] FPT DRAIN  10'-1" [3073] 11'-4 1/2" [3467]	
SHIPPING WEIGHT 12300 lbs+ [5580] kg+ OPERAT WEIGH	<sup>ING</sup> 26490 lbs+ [12020] kg+	HEAVIEST SECTION 12300 lbs+ [5580] kg+	NO. OF SHIPPING SECTIONS 1 DRAWN BY: J	JLM